



Government of West Bengal
Department of Fire and Emergency Services
2nd& 3rd floor, New Town Fire Station Building
Action Area 1C, Block CF 7, Street No. 175
New Town, Kolkata 700 156

No.1590/FES-99/101/2025

Date:09 /12/2025

ORDER

The State Government has been considering to provide relief to some of the very small, single storied establishments under the low hazard occupancies which comes under notification No. 1930/FES/O/MISC-08/2023, dated 01/03/2024 by the way of issuance of instant and real time online 'Spot Fire License' without any inspection;

Now, the Governor is hereby pleased to introduce instant and real time online 'Spot Fire License' system for the following categories of single storied establishments intending to handle/process/store very less quantity of hazardous substances after maintaining the bare minimum fire safety measures as detailed below. The real time 'Spot Fire License' shall be an auto-generated document from the system without any physical inspection; and shall remain valid for a period of 5(five) years from the date of its issue.

However, there will be a post-verification of such real time auto generated fire licenses afterwards, on random basis, at the field level. In case it is detected after field verification that such spot fire licenses are procured by intentionally providing any false information into the system or the applicant occupancy is not at all entitled to avail such facility of such spot fire license without any physical inspection, the applicant shall be prosecuted by the law in force; and the concerned spot fire license so issued shall be considered as invalid and terminated.

The single storied establishments and the quantity of hazards which shall come under the purview of availing the facility of real time spot fire license after maintaining specified minimum fire safety measures are given below: -

Type of the single storied establishment	Max. Quantity of hazardous articles allowed	Max. Area allowed	Minimum fire safety measures (all extinguisher store pressure type)
Roll centre/fast food centre	40 kg LPG	Within 500 sqft, no seat	2 ABC (4.5 kg)
Rice hotel/tea shop	40 kg LPG, 50 kg coal	Within 200 sqft, 10 seat	1 ABC (4.5 kg). 1 water type (9 litre)
Sweet shop	40 kg LPG	Within 500 sqft	2 ABC (4.5 kg)
Medicine shop/store	Packing box/plastic-100 kg	Within 500 sqft	1 ABC (4.5 kg). 1 water type (9 litre)
Restaurant	40 kg LPG, 50 kg coal/charcoal	Within 500 sqft, 10 seat	1 ABC (4.5 kg). 1 water type (9 litre)
Cafe	Packing box- 20 kg, 20 kg LPG	Within 500 sqft, 10 seat	1 ABC (4.5 kg). 1 water type (9 litre)

Hardware shop	Packing box-200 kgs, paint-200 ltr, varnish, resin, paint thinner-50 ltr each, tar, tallow, pitch, shellac- 2 kg (for each) Jute, gunny bag, cotton, hemp-each 50 kg, spirit-50 ltr	Within 1000 sqft	1 foam (9 litre), 1 ABC (4.5 kg). 1 water type (9 litre)
Hallmark centre	20 litre Nitric Acid/HCl/Sulphuric Acid	Within 500 sqft	2 ABC (4.5 kg)
Car repairing shop	100 litre fuel and 50 litre lubricating, 1 no LPG, 1 no oxyacetelene cylinder	Within 1000 sqft	1 foam (9 litre), 1 ABC (4.5 kg)
Bike repairing shop	Petrol and petroleum derivatives-50 litre, lubricant-25 litre	Within 500 sqft	1 foam (9 litre), 1 ABC (4.5 kg)
Tailoring shop	Cotton-200 kgs	Within 500 sqft	1 ABC (4.5 kg), 1 water type (9 litre)
Paint shop	Paint-500 litre, paint thinner-200 litre, turpentine oil-50 ltr	Within 500 sqft	1 foam (9 litre), 1 ABC(4.5 kg), 1 water type (9 litre)
Shop	Linseed oil 100 litre	Within 500 sqft	1 foam (9 litre), 1 ABC (4.5 kg),
Furniture shop	Wood-2000 kg	Within 1000 sqft	1 CO ₂ (4.5 kg) gas type, 2 water type (9 litre)
Pathological lab	Ethyl alcohol-50 litre, cotton-10 kg, packing box/plastic-10 kg	Within 500 sqft	1 CO ₂ (4.5 kg) gas type, 1 water type (9 litre)
Book binding shop	Paper-1000 kg	Within 500 sqft	1 CO ₂ (4.5 kg) gas type, 2 water type (9 litre)
Book shop	Paper-500 kg	Within 200 sqft	1 CO ₂ (4.5 kg) gas type, 2 water type (9 litre)
Garment shop	Cotton-1000 kg, packing box/plastic-50 kg	Within 500 sqft	1 ABC (4.5 kg), 2 water type (9 litre)
Packing box manufacturing unit	Paper and cardboard-100 kg	Within 1000 sqft	1 ABC (4.5 kg). 2 water type (9 litre)
Engineering workshop	1 no LPG, 1 no Oxy-acetylene cylinder	Within 500 sqft	1 ABC(4.5 kg), 1 CO ₂ (4.5 kg) gas type
Grill manufacturing unit	1 no LPG, 1 no oxygen (industrial) cylinder	Within 1000 sqft	1 ABC (4.5 kg), 1 CO ₂ (4.5 kg) gas type
Catering service unit	LPG-40 kg, coal-50 kg	Within 200 sqft	1 ABC (4.5 kg). 1 CO ₂ (4.5 kg) gas type
Home delivery	LPG-40 kg, coal-50 kg	Within 200 sqft	1 ABC (4.5 kg), 1 CO ₂ (4.5 kg) gas type
Small office	Diesel for generator-100 litre	Within 200 sqft	1 foam (9 litre),

			1 ABC (4.5 kg)
Electronics shop/repairing centre	Packing box/plastic-50 kg	Within 200 sqft	1 ABC (4.5 kg), 1 water type (9 litre)
Homeopathy medicine shop	Ethyl alcohol-50 litre, packing box/plastic-50 kg	Within 200 sqft	1 ABC (4.5 kg). 1 water type (9 litre)
Small homeopathy medicine manufacturing unit	Ethyl alcohol-50 litre, packing box/plastic-10 kg	Within 200 sqft	1 ABC (4.5 kg). 1 water type (9litre)
Confectionery	LPG 40 kg	Within 200 soft	1 ABC(4.5 kg), 1 CO ₂ (4.5 kg) gas type
Xerox shop	Paper-50 kg	Within 200 sqft	1 ABC (4.5 kg), 1 water type (9 litre)
Tyre shop	Rubber-50 kg	Within 200 sqft	1 ABC (4.5 kg), 1 water type (9 litre)
Management service provider	LPG 40 kg, coal 50 kg	Within 200 sqft	1 ABC (4.5 kg), 1 CO ₂ (4.5 kg) gas type
Printing press	Paper 100 kg, plastic 10 kg	Within 500 sqft	1 ABC (4.5 kg), 1 water type (9 litre)
Car/bike showroom	Petrol/diesel-200 litre, lubricant-20 litre	Within 500 sqft	1 foam (9 litre), 1 ABC (4.5 kg)
Small workshop of plastic product manufacturing unit using one (1) injection moulding machine	Plastic-250 kg	Within 250 sqft	1 ABC (4.5 kg), 1 water type (9 litre)


Applicant occupancies falling under the above category of establishments and located in a single storied building only shall be entitled to avail the facility of real time spot license upto the maximum quantity of hazardous substances mentioned in the table through e-District platform.

If the applied hazardous quantum of articles falls within the exempted quantity, as notified by this Department earlier, need not be required to apply for fire license; and the portal will show a message to that effect.

The applicant occupancy has to submit an undertaking in the system during submission of online application that whatever information submitted in the application about the establishment, its area, quantity of hazardous article(s), minimum safety measures already undertaken *etc* are true, and will take full and complete responsibility of submitting any false or misinformation.

After submission of the application, the applicant will get an instant auto-generated demand followed by an instant auto-generated spot fire license for the applied quantity of hazardous items for 5 years on payment of the demand amount from the portal.

This order is issued in the interest of public with immediate effect.


(Utpal Bhadra, IAS)

Senior Special Secretary to the Govt. of West Bengal

Copy forwarded for information and necessary action to –

1. The Chief Secretary to the Govt. of West Bengal, Nabanna, 325, Sarat Chatterjee Road,Hawrah 711 102;
2. The Additional Chief Secretary to the Govt. of West Bengal, Home & Hill Affairs Department, Nabanna, 325,Sarat Chatterjee Road,Hawrah 711 102;
3. The Additional Chief Secretary to the Govt. of West Bengal, MSME&T Department, Nabanna, 325,Sarat Chatterjee Road,Hawrah 711 102;
4. The Additional Chief Secretary to the Govt. of West Bengal, Public Works Department, Nabanna, 325,Sarat Chatterjee Road, Hawrah 711 102;
5. The Director General, WBF&ES, 13 D, Mirza Galib Street, Kolkata 700 016;
6. The Additional Director General, WBF&ES, 13 D, Mirza Galib Street, Kolkata 700 016;
7. The District Magistrate(s), (All).....;
8. The Sr. P.S. to the Hon'ble MOS (IC), Department of Fire and Emergency Services;
9. The Special Law Officer & ex-officio Deputy Secretary (Law), Department of Fire and Emergency Services;
10. The Commissioner of Police, Kolkata, Lalbazar,
11. The Director (In Charge), WBF&ES, 13 D, Mirza Galib Street, Kolkata 700 016;
12. The Assessing and Legal Officer & ex-officio Additional Director (Assessing & Legal), WBF&ES, 13 D, Mirza Galib Street, Kolkata 700 016;
13. The Deputy Director(s), WBF&ES, (All)
.....;
14. The Divisional Fire Officer(s), WBF&ES, (All)
.....;
15. The Sr. P.S. to the Additional Chief Secretary to the Govt. of West Bengal, Department of Fire and Emergency Services;
16. Guard File.


(Sanjay Banerjee)

Deputy Secretary to the Govt. of West Bengal